

110

Wiltshire Steeplejacks

The Coach House 5 Court Street Trowbridge Wiltshire BA14 8BR Tel 01225 761330 07973 397770

TEST CERTIFICATE

Test Certificate Number **10281**
 Date **21/05/2018**
 Building Name or Number **67-72 EASTBURY WAY SWINDON**

Information

Next Test Due May, 2019
Test Instrument DET5/4D
Calibration Date October 31, 2017
Certificate No. STD47640
The Lightning Protection System has been electrically tested with the British Standard Code of Practice for Churches and Public building BSEN 62305-2008 and must be tested annually to comply with the Code of Practice, and should not exceed 10 ohms (Parallel Average)

Customer Details

Name MRS CLEARY
Address (line 1) 64 EASTBURY WAY
Address (line 2)
City SWINDON
Postal code, Country SN25 2EW
Phone

Company name KESWICK HOUSE
 RTM.CO.LTD

Test Reading	ohms	Test Reading	ohms
1	12.70	31	
2	16.20	32	
3	16.80	33	
4	19.10	34	
5	13.60	35	
6	17.30	36	
7		37	
8		38	
9		39	
10		40	
11		41	
12		42	
13		43	
14		44	
15		45	
16		46	
17		47	
18		48	
19		49	
20		50	
21		51	
22		52	
23		53	
24		54	
25		55	
26		56	
27		57	
28		58	
29		59	
30		60	

PASSED / FAILED PASSED
Defects to be reported:
 THE AERIAL ON THIS PREMISES REQUIRES BONDING TO THE SYSTEM AS IT IS THE MOST VULNERABLE POINT ON THIS BUILDING
 THIS WORK FOR THE SUM OF £285.00 PLUS VAT

Engineers Name T MURDEN

T MURDEN
 Engineers Signature

Average **0.38**
 Parallel Average **2.61**