

Wiltshire Steeplejacks

The Coach House 5 Court Street Trowbridge Wiltshire BA14 8BR Tel 01225 761330 07973 397770

TEST CERTIFICATE

Test Certificate Number **10787**
 Date **01/05/2019**
 Building Name or Number **67-72 EASTBURY WAY SWINDON**

Information

		Test Reading	ohms	Test Reading	ohms
<i>Next Test Due</i>	May, 2020	1	13.60	31	
<i>Test Instrument</i>	meggar DET5\4D	2	11.50	32	
<i>Calibration Date</i>	November 13, 2018	3	14.80	33	
<i>Certificate No.</i>	PCS45424	4	15.10	34	
<i>The Lightning Protection System has been</i>		5	18.60	35	
<i>electrically tested with the British Standard Code</i>		6	17.30	36	
<i>of Practice for Churches and Public building</i>		7		37	
<i>BSEN 62305-2008 and must be tested annually to</i>		8		38	
<i>comply with the Code of Practice, and</i>		9		39	
<i>should not exceed 10 ohms (Parallel Average)</i>		10		40	
		11		41	
		12		42	
Customer Details					
<i>Name</i>	MRS CLEARY	13		43	
<i>Address (line 1)</i>	64 EASTBURY WAY	14		44	
<i>Address (line 2)</i>		15		45	
<i>City</i>	SWINDON	16		46	
<i>Postal code, Country</i>	SN25 2EW	17		47	
<i>Phone</i>		18		48	
		19		49	
<i>Company name</i>	KESWICK HOUSE	20		50	
	RTM.CO.LTD	21		51	
		22		52	
		23		53	
PASSED / FAILED	PASSED	24		54	
Defects to be reported:		25		55	
THE AERIAL ON THIS PREMISES REQUIRES BONDING		26		56	
TO THE SYSTEM AS IT IS THE MOST VULNERABLE		27		57	
POINT ON THIS BUILDING		28		58	
THIS WORK FOR THE SUM OF £285.00 PLUS VAT		29		59	
		30		60	

Engineers Name T MURDEN

Average

0.41

T MURDEN

Parallel Average

2.46

Engineers Signature